

CE TEST CERTIFICATE

FOR PERFORMANCE CHARACTERISTICS OF CONSTRUCTION PRODUCTS FOR THE CE MARKING

BOD-17-07-10-02

- Products:** PVC Flooring "Vinyl Tile Flooring"
Dimensions: Length (100-2000) mm x Width (100-610) mm x Thickness (2.0-6.0) mm
- Client:** JiangSu Zhengyoung Flooring Decoration Material Co., Ltd.
No. 32 Cuibei Village, Henglin Town, Wujin Dist, Changzhou City; Jiangsu Prvince,
Postcode 213101, China
- Order:** Testing and classification of selected properties according to EN 14041:2008 (CE-labelling)
- Test report:** 278003/79
- Test results:** *The above mentioned PVC floorings can be classified regarding to both properties according to EN 14041:2008 (CE-labelling) as follows:*

Properties	Results	Declaration according to EN 14041:2008
Reaction to fire performance according to EN ISO 9239-1 and EN ISO 11925-2, Classification according to EN 13501-1:2010 - Critical heat flow - Smoke production	11.6 kW / m ² 273 % x min	Reaction to fire class B _{fl} -s1
Sliding behaviour according to EN 13893:2003	$\mu = 0.41 - 0.42$	class DS

Dresden, 10 July 2017

Head of laboratory



Engineer in charge